



NATIONAL ACADEMIES Sciences Engineering Medicine

SMS SUMMIT 2023

WELDER

WEATHER EFFECTS ON LIFECYCLE DEGRADATION AND EQUIPMENT REPLACEMENT


Engineering Track: Session 3B
Tuesday, Aug 8 – 3:00 – 3:50 PM





U.S. ARMY



US Army Corps of Engineers®



Hurricane Michael – S-NPP – I-Band 5 - 11µm
10 October 2018, 2:32am CDT






U.S. ARMY


CLIMATE IMPACTS ON THE BUILT ENVIRONMENT



Tornado damage at Fort Leonard Wood, MO (2011)



Hurricane Michael damage at Tyndall AFB, FL (2018)




Flooding at Offutt AFB, NE (2019)





U.S. ARMY


ASSESSING BUILDING COMPONENT CONDITION AND SERVICE LIFE



Component Inventory




Condition/ Functionality Assessment



Performance Metrics and Forecasting Models



Work Requirements



Consequence Analysis and Reporting

BUILDER SMS: A structured process for collecting, synthesizing, and organizing **information** about civil infrastructure and facility assets to support decisions pertaining to their **sustainment** over their lifecycle






BUILDING COMPONENT INVENTORY



U.S. ARMY

System	Sub-System	Component	Component Type	Name	Quantity	UM	Year
A 10 FOUNDATIONS	A 1010 STANDARD FOUNDATIONS	A 101001 WALL FOUNDATIONS	Strip Footing		30	LF	1957
A 10 FOUNDATIONS	A 1010 STANDARD FOUNDATIONS	A 101002 COLUMN FOUNDATIONS & PILE CAPS	Spread Footing		21	EA	1957
B20 EXTERIOR ENCLOSURE	B2010 EXTERIOR WALLS	B201001 EXTERIOR CLOSURE	Concrete Block		3,500	SF	1957
B20 EXTERIOR ENCLOSURE	B2020 EXTERIOR WINDOWS	B202001 WINDOWS	Steel Window s		10	EA	1957
B20 EXTERIOR ENCLOSURE	B2030 EXTERIOR DOORS	B203001 SOLID DOORS	Steel		17	EA	1957
B30 ROOFING	B3010 ROOF COVERINGS	B301002 LOW SLOPE ROOF SYSTEMS	Built-Up		8,196	SF	2003
C10 INTERIOR CONSTRUCTION	C1010 PARTITIONS	C101001 FIXED PARTITIONS	Wall - Concrete Block		890	SF	1957
C10 INTERIOR CONSTRUCTION	C1010 PARTITIONS	C101001 FIXED PARTITIONS	Wall - Dryw all w /Stud Framing		1,780	SF	1957
C10 INTERIOR CONSTRUCTION	C1020 INTERIOR DOORS	C102001 STANDARD INTERIOR DOORS	Wood Door/Metal Frame		27	EA	1957
D30 HVAC	D3020 HEAT GENERATING SYSTEMS	D302001 BOILERS	Gas, Hot Water - 500-650 MBH B-1		1	EA	2000
D30 HVAC	D3020 HEAT GENERATING SYSTEMS	D302004 AUXILIARY EQUIPMENT	Expansion Tank - 40 gal	ET	1	EA	1987
D30 HVAC	D3030 COOLING GENERATING SYSTEMS	D303001 CHILLED WATER SYSTEMS	Chiller, Reciprocating, Water Cooled - 60 TN	CH	1	EA	2001
D30 HVAC	D3030 COOLING GENERATING SYSTEMS	D303001 CHILLED WATER SYSTEMS	Cooling Tow er, Galvanized - 60 TN		1	EA	1997
D30 HVAC	D3040 DISTRIBUTION SYSTEMS	D304007 EXHAUST SYSTEMS	Fan System, Wall Exhaust - Wall Exhaust, 6175 CFM	EF-1	1	EA	1998
D30 HVAC	D3040 DISTRIBUTION SYSTEMS	D304008 AIR HANDLING UNITS	Central Station - 10000 CFM	AHU-1	1	EA	2001
D30 HVAC	D3050 TERMINAL & PACKAGE UNITS	D305006 PACKAGE UNITS	A/C Unit, Split Systems w / Air Cooled Condenser - 3 TN	AC-2	2	EA	1997
D30 HVAC	D3050 TERMINAL & PACKAGE UNITS	D305006 PACKAGE UNITS	Heat Pump, Air Source, Roof Top - 10 ton	HP-4	1	EA	1990



Source: GAO presentation of Department of Defense information, Texas Livvyistock.adobe.com | GAO-22-104481






STANDARDIZED CONDITION ASSESSMENT



Distress Type(s): Deteriorated
Severity Level(s): Low
Quantity/Density: 200 SF

Distress Type(s): Cracked
Severity Level(s): Med
Quantity/Density: 12 LF



RATING	CI VALUE	RATING DEFINITION
GREEN (+)	100	ENTIRE COMPONENT FREE OF OBSERVABLE DISTRESSES. LIKE NEW CONDITION.
GREEN	95	NO SERVICEABILITY OR RELIABILITY REDUCTION. SLIGHT DEGRADATION BUT NON-CRITICAL. NO WORK OTHER THAN ROUTINE MAINTENANCE.
GREEN (-)	88	SLIGHT OR NO SERVICEABILITY OR RELIABILITY REDUCTION. SOME NOTICEABLE DEGRADATION BUT NON-CRITICAL. NO WORK OTHER THAN ROUTINE MAINTENANCE.
AMBER (+)	80	SERVICEABILITY OR RELIABILITY IS DEGRADED, BUT STILL ADEQUATE. MODERATE DETERIORATION BUT NON-CRITICAL. MINOR REPAIRS NEEDED.
AMBER	71	SERVICEABILITY OR RELIABILITY IS NOTICEABLY IMPAIRED. MODERATE DETERIORATION OR DAMAGE REQUIRES CORRECTIVE REPAIRS.
AMBER (-)	61	SIGNIFICANT SERVICEABILITY OR RELIABILITY LOSS. SIGNIFICANT DEGRADATION OR DAMAGE REQUIRES MAJOR REHABILITATION OR OVERHAUL.
RED	30	SEVERE SERVICEABILITY OR RELIABILITY REDUCTION MAY RESULT IN LOSS OF USE OR SAFETY. IMMEDIATE REPLACEMENT WARRANTED.






U.S. ARMY



CONDITION AND SERVICE LIFE FORECASTING



Degradation/Shape parameter



Scale/Service Life parameter



Adaptive model predicts performance of each unique component; identifies best time to invest





U.S. ARMY

QUESTION: CLIMATE EFFECTS ON DEGRADATION?



Building Components

- Foundation
- Super Structure
- HVAC
- Rooftop AC Unit
- ...

Hazard Events


- Severe Storm
- Extreme Heat
- ...

Stressors


- Excessive Wind
- Increased CCDs
- Increased Temp Intensity
- ...

Damage/Distress Mode	Damage Type	Damage Effect	Weather Variable
Equipment Damage due to excess Wind	Abrupt	Condition Loss / Failure	CDDs
Accelerated HVAC equipment degradation due to increases demand	Gradual	Service Life Reduction	Annual Days above 100
HVAC Equipment failure due to prolonged run-time	Abrupt	Condition Loss / Failure	Wind Speed

Failure distribution vs Age



Expected Condition vs Age






U.S. ARMY


CLIMATE DATA / WEATHER EVENT MODELING






Weather Research and Forecasting (WRF) model simulations at 3km resolution



Site-specific Forecasted Weather Metrics



WRF Tropical Channel Model simulations at 27km resolution







U.S. ARMY

EXPLORING LINKAGE BETWEEN CDDs AND FAILURE AGE


Projected CDD change 2005-2060




Failure Distribution by CDD bins




Air-Handler Avg. Failure Age vs. CLDD




Boosted Decision Tree Approach



Relative Influence of Model Predictor Variables




AHU Service Life Comparison





U.S. ARMY


WEATHER EFFECTS ON THE LIFECYCLE OF DOD EQUIPMENT REPLACEMENT (WELDER)





U.S. ARMY

WELDER: COMPONENT LEVEL IMPACT ANALYSIS



Component Service Life Reduction

Based on weather-related damage





U.S. ARMY

WELDER: COMPONENT RISK INDICATORS



WELDER

Climate Recon Help/Documentation Log Out

Organizations: W Nicholas Sites: Phenix, Avinger, Barrington, Lafitte, Callisburg, Colfax, West Baden Springs, Laguna Heights, El ... Complexes - N/A

Scenario List > Organizations > Barrington > Boathouse

Scenario

IMCOM_B30_only

Only B30 for all of IMCOM

Years: 3 Hazards:

Filter:

Facility

Boathouse

Facility Number: 00126

Year Constructed: 1975

Climate Model Location

Risk Analysis

Total PRV: \$1,588.53

Risk Premium: \$126

Risk Rating: High

50th Percentile 90th Percentile

Percentile: 50% (90%) likelihood that the actual risk premium falls below the estimated risk premium.

Components

Component	Material Category	Component Type	Name	Quantity	SL Reduction	Annual Risk Premium	Avg Risk Rating
D3030 COOLING GENERATING SYSTEMS	D303004 AUXILIARY EQUIPMENT	Expansion Tank - 240 gal	MECH RM	1 EA	0.86	54	Medium
D3030 COOLING GENERATING SYSTEMS	D303004 AUXILIARY EQUIPMENT	Chemical Feedwater - 150 lb., 5 gallon, ASME	MECH RM	1 EA	0.92	45	Low
D3030 COOLING GENERATING SYSTEMS	D303001 CHILLED WATER SYSTEMS	Chiller, Scroll - 100 TN	SOUTH CHC-01	1 EA	0.89	18	Low
D3030 COOLING GENERATING SYSTEMS	D303004 AUXILIARY EQUIPMENT	Expansion Tank - 24 gal	MECH RM	1 EA	0.87	10	Medium
B2020 EXTERIOR WINDOWS	B202001 WINDOWS	General	ALUMINUM 7	138.52 SF	0.00	0	Very Low
C1020 INTERIOR DOORS	C102001 STANDARD INTERIOR DOORS	Metal Door	ELEC RM	1 EA	0.00	0	Very Low

Service Life Reduction results in annual risk premium for each component — aggregated to building and site levels

Component Risk Rating — based on ratio of annual risk premium to component replacement value





U.S. ARMY

WELDER: BUILDING RISK INDICATORS



WELDER | Climate Recon | Help/Documentation | Log Out

Organizations: W Nicholas | Sites: Phenix, Avinger, Barrington, Lafitte, Callisburg, Colfax, West Baden Springs, Laguna Heights, El ... | Complexes - N/A

Scenario: IMCOM_B30_only | Only B30 for all of IMCOM | Years: 3 | Hazards: | Filter: Systems All, Components All

Site: Barrington | Number of Buildings: 507

Risk Analysis

Total PRV: \$2.09 B

Risk Premium: \$19.58 M (50th Percentile), \$348.77 M (90th Percentile)

Risk Rating: High (indicated by a needle on a gauge)

Climate Model Location

Facilities

RPUID	Building Number	Name	Year	Category Code	PRV	Annual Risk Premium	Avg Risk Rating
246929	00126	Boathouse	1975	6412	1,589	126	Very High
896908	01194	Water Tower	1974	2386	433,159	8,434	High
19415	08162	Garage	1967	2402	459,387	7,752	High
923759	01227	Observatory	1975	1055	760,318	3,510	Low
109100	02117	Clinic	1968	152	1.02 M	3,402	Low
296957	61008	Marina	2005	6511	35,269	74	Low
752914	07332	Silo	1974	549	95,852	136	Low
640613	01250	Garage	1938	6527	669,332	610	Very Low
313169	00842	Dormitory	1971	12299	2.16 M	1,545	Very Low
623515	06227	Fire Station	1977	2025	5.07 M	3,311	Very Low
151160	00227	Chapel	1969	2718	163,101	101	Very Low
131805	61402	Recycling Center	2004	12112	480,619	294	Very Low
560289	08380	Dormitory	2003	11095	605,152	341	Very Low

Facility risk rating based on ratio of annual risk premium to Plant Replace Value

List of Individual Facilities at Site – Clicking on a facility goes to analysis details





WELDER CLIMATE LIFECYCLE IMPACT

U.S. ARMY

14



Calculation Steps

- Step 1. Component Level Info
- Step 2. Calculate Component Metrics
- Step 3. Get Damage Modes and model parameters for component Types
- Step 4. Find Baseline Climate Variables for each Damage Mode
- Step 5. Given a percentile assumption, Find Climate Value Change for each Damage Mode
- Step 6a. Calculate Climate Impact Metrics for Gradual Damage Types
- Step 6b. Calculate Climate Impact Metrics for abrupt Damage Types
- Step 7. Aggregate Service Life Reduction across all damage modes
- Step 8. Calculate weather adjusted degradation parameters across all damage modes
- Step 9. Calculate Annual Risk Premium




STEP 1. COMPONENT LEVEL INFO




Given a building component in service in a building, we have certain information about that component in BUILDER, including:


- Building Location: Geographic Location building
- Component Type: Specific Type that component is classified as
- Quantity: The quantity of the component
- Year Installed: Year component was installed or placed in service
- Component Replacement Value: The estimated cost to replace the component
- Design Life: The expected service life of the component from install to replacement
- Alpha: The condition degradation shape parameter
- Beta: The condition degradation scale parameter



Degradation/Shape parameter



Scale/Service Life parameter





Organizations: W Nicholas

Sites: Phenix, Avinger, Barrington, Lafitte, Callisburg, Colfax, West Baden Springs, Laguna Heights, El...

Complexes: N/A

Scenario List > Organizations > Avinger > Workshop > Component > Calculation Details

Scenario ⓘ

IMCOM_B30_only

Only B30 for all of IMCOM

Years: 3 Hazards:

Filter

Systems All

Components All

Component Info

Component: **D3030 COOLING GENERATING SYSTEMS**

Material Category: **D303001 CHILLED WATER SYSTEMS**

Component Type: **Cooling Tower, Stainless Steel - 1000 TN**

Replacement Value: **\$686,880.00**

Year Built: **2019**

Age: **3**

Design Life: **15**

Quantity: **1 EA**

Alpha: **1.40**

Beta: **0.89**

Component Metrics

Current Age: **3**



Current CI: **89.2**

Effective Age: **6.82**

Remaining Design Life (RDL): **12**

Remaining Service Life (RSL): **10.3**

Model Year (CurrentYear + RSL): **2030**





STEP 2. CALCULATE COMPONENT METRICS



Based on this information, BUILDER calculates various metrics used to inform planning decisions, including:

- Current Age: $CurrentYear - YearInstalled$
- Current CI: $100 \times \left(\frac{100}{CI_{terminal}}\right)^{-\left(\frac{CurrentAge}{DesignLife \times beta}\right)^{alpha}}$
- Effective Age: $DesignLife \times \left(-Log\left(\frac{CurrentCI}{100}, \frac{100}{40}\right)\right)^{\left(\frac{1}{alpha}\right)}$
- Remaining Design Life: $DesignLife - CurrentAge$
- Remaining Service Life: $DesignLife - EffectiveAge$



Organizations: W Nicholas
 Sites: Phenix, Avinger, Barrington, Lafitte, Callisburg, Colfax, West Baden Springs, Laguna Heights, El...
 Complexes - N/A

Scenario List > Organizations > Avinger > Workshop > Component > Calculation Details

Scenario ⓘ

IMCOM_B30_only

Only B30 for all of IMCOM

Years: 3
 Hazards: 0

Filter

Systems All

Components All

Component Info

Component: **D3030 COOLING GENERATING SYSTEMS**

Material Category: **D303001 CHILLED WATER SYSTEMS**

Component Type: **Cooling Tower, Stainless Steel - 1000 TN**

Replacement Value: **\$686,880.00**

Year Built: **2019**

Age: **3**

Design Life: **15**

Quantity: **1 EA**

Alpha: **1.40**

Beta: **0.89**

Component Metrics

Current Age: **3**




Current Cl: **89.2**

Effective Age: **6.82**

Remaining Design Life (RDL): **12**

Remaining Service Life (RSL): **10.3**

Model Year (CurrentYear + RSL): **2030**









U.S. ARMY

STEP 3. GET DAMAGE MODES AND MODEL PARAMETERS FOR COMPONENT TYPES

For each component type, a damage association table lists applicable damage modes and associated model parameters

- Damage Mode: A description of the damage type
- Mode Type: Whether the damage mode is abrupt or gradual
- Stressor: The climate factor associated to the damage mode
- Climate Variable: The climate variable that measures intensity of the stressor
- Threshold: The level of the climate variable that is typically results in the damage mode if exceeded.
- Damage Likelihood: The likelihood of damage mode occurring given climate variable threshold is met
- Damage Factor: the extent of the damage on component service, ranging from no effect on condition an/or service life to total loss of component.



Damage Modes			
Climate Variable	Max Temperature	Cooling Degree Days	Rainfall (in/day)
Damage Mode	Excessive Runtime for HVAC Cooling Systems	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services
Damage Type	Abrupt	Gradual	Abrupt
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss
Threshold	100	65	6
Damage Likelihood	0.75	0.25	0.25
Damage Extent	0.05	0.5	0.8
Baseline	12.16	923.22	0.00

Totals




U.S. ARMY

STEP 4. FIND BASELINE CLIMATE VARIABLES FOR EACH DAMAGE MODE



When evaluating a damage mode for a given component:

- Find the climate dataset closest to the building location
- Specific Climate Variable
- Specific Climate threshold for damage mode
- Year = Component Year installed (or 2005 if installed prior to 2005)
- Select the climate value for the 50%. This represents the baseline climate value at or near the beginning of the component's service life



Damage Modes

Climate Variable	Max Temperature	Cooling Degree Days	Rainfall (in/day)	Totals
Damage Mode	Excessive Runtime for HVAC Cooling Systems	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services	
Damage Type	Abrupt	Gradual	Abrupt	
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss	
Threshold	100	65	6	
Damage Likelihood	0.75	0.25	0.25	
Damage Extent	0.05	0.5	0.8	
Baseline	12.16	923.22	0.00	
50th Percentile				
Climate Value	17	1,020.53		
Annualized Increase		0.01		
Degradation Rate		105.27%		
Adjusted RSL		9.81		
Adjusted Alpha		1.43		
Adjusted Beta		0.85		0.83
SL Reduction	0.38	0.52		0.9
Annual Risk Premium				3,997
90th Percentile				
Climate Value	30.1	1,171.28	0.89	
Annualized Increase		0.03		
Degradation Rate		113.43%		
Adjusted RSL		9.1		
Adjusted Alpha		1.49		1.66
Adjusted Beta		0.81		0.7
SL Reduction	0.39	1.22	1.22	2.83
Annual Risk Premium				12,538




STEP 5. GIVEN A PERCENTILE ASSUMPTION, FIND CLIMATE VALUE CHANGE FOR EACH DAMAGE MODE



Now find the change in the climate variable value over its expected service life. This change depends on whether evaluating at a 50% probability level (50% probability of value not being exceeded) or a more risk averse 90% probability level (90% probability of value not being exceeded).

- Find the climate dataset closest to the building location
- Specific Climate Variable
- Specific Climate threshold for damage mode
- $\text{Year} = \text{CurrentYear} + \text{RemainingServiceLife}$
- Select the climate value for the desired confidence level. This represents the projected climate value at or near the end of the component's service life.
- ClimateValueChange: *ProjectedClimateValue* – *BaselineClimateValue*



Damage Modes


Climate Variable	Max Temperature	Cooling Degree Days	Rainfall (in/day)	Totals
Damage Mode	Excessive Runtime for HVAC Cooling Systems	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services	
Damage Type	Abrupt	Gradual	Abrupt	
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss	
Threshold	100	65	6	
Damage Likelihood	0.75	0.25	0.25	
Damage Extent	0.05	0.5	0.8	
Baseline	10.16	600.00	0.00	
50th Percentile				
Climate Value	17	1,020.53		
Annualized Increase		0.01		
Degradation Rate		105.27%		
Adjusted RSL		9.81		
Adjusted Alpha		1.43		
Adjusted Beta		0.85		0.83
SL Reduction	0.38	0.52		0.9
Annual Risk Premium				3,997
90th Percentile				
Climate Value	30.1	1,171.28	0.89	
Annualized Increase		0.05		
Degradation Rate		113.43%		
Adjusted RSL		9.1		
Adjusted Alpha		1.49		1.66
Adjusted Beta		0.81		0.7
SL Reduction	0.39	1.22	1.22	2.83
Annual Risk Premium				12,538



STEP 6A. CALCULATE CLIMATE IMPACT METRICS FOR GRADUAL DAMAGE TYPES

For gradual damage mode types, calculate service life reduction as follows:

- Annualized Increase: $\frac{ClimateValueChange}{BaselineValue \times RemainingServiceLife}$
- Degradation Rate: $1 + AnnualizedIncrease \times DamageFactor \times RemainingServiceLife$
- Adjusted RSL: $\frac{RemainingServiceLife}{DegradationRate}$
- Adjusted Beta: If $RSL \leq 0$, then $\frac{CurrentAge + AdjustedRSL}{DesignLife}$, else beta
- Adjusted Alpha: $Log\left(-Log\left(\frac{CurrentCI}{100}, \frac{100}{CIterminal}\right)\right), \frac{CurrentAge}{DesignLife \times AdjustedBeta}$
- Service Life Reduction: If $RSL > 0$, 0, else $RemainingServiceLife - AdjustedRSL$



Climate Variable	Damage Modes			
	Max Temperature	Cooling Degree Days	Rainfall (in/day)	Totals
Damage Mode	Excessive Runtime for HVAC Cooling Systems	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services	
Damage Type	Abrupt	Gradual	Abrupt	
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss	
Threshold	100	65	6	
Damage Likelihood	0.75	0.25	0.25	
Damage Extent	0.05	0.5	0.8	
Baseline	12.16	923.22	0.00	
50th Percentile				
Climate Value	17	1,020.53		
Annualized Increase		0.01		
Degradation Rate		105.27%		
Adjusted RSL		9.81		
Adjusted Alpha		1.43		
Adjusted Beta		0.85		0.83
SL Reduction	0.38	0.52		0.9
Annual Risk Premium				3,997
90th Percentile				
Climate Value	30.1	1,171.28	0.89	
Annualized Increase		0.03		
Degradation Rate		113.43%		
Adjusted RSL		9.1		
Adjusted Alpha		1.49		1.66
Adjusted Beta		0.81		0.7
SL Reduction	0.39	1.22	1.22	2.83
Annual Risk Premium				12,538



U.S. ARMY


STEP 6B. CALCULATE CLIMATE IMPACT METRICS FOR ABRUPT DAMAGE TYPES



27

For abrupt damage mode types, calculate service life reduction as follows:

- Service Life Reduction: If $RSL \leq 0$, 0, else $RemainingServiceLife \times DamageLikelihood \times DamageFactor \times (1 - (\frac{365 - ClimateValueChange}{365})^{365})$



Damage Modes				
Climate Variable	Max Temperature	Cooling Degree Days	Rainfall (in/day)	Totals
Damage Mode	Excessive Runtime for HVAC Cooling System	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services	
Damage Type	Abrupt	Gradual	Abrupt	
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss	
Threshold	100	65	6	
Damage Likelihood	0.75	0.25	0.25	
Damage Extent	0.05	0.5	0.8	
Baseline	12.16	923.22	0.00	
50th Percentile				
Climate Value	17	1,020.53		
Annualized Increase		0.01		
Degradation Rate		105.27%		
Adjusted RSL		9.81		
Adjusted Alpha		1.43		
Adjusted Beta		0.85		0.83
SL Reduction	0.38	0.52		0.9
Annual Risk Premium				3,997
90th Percentile				
Climate Value	30.1	1,171.28	0.89	
Annualized Increase		0.03		
Degradation Rate		113.43%		
Adjusted RSL		9.1		
Adjusted Alpha		1.49		1.66
Adjusted Beta		0.81		0.7
SL Reduction	0.39	1.22	1.22	2.83
Annual Risk Premium				12,538



U.S. ARMY


STEP 7. AGGREGATE SERVICE LIFE REDUCTION ACROSS ALL DAMAGE MODES

29



If there are multiple damage modes applicable for a component, aggregate service life reduction across all n damage modes:

- Total Service Life Reduction: $\sum_n^1 ServiceLifeReduction$



Damage Modes				
Climate Variable	Max Temperature	Cooling Degree Days	Rainfall (in/day)	Totals
Damage Mode	Excessive Runtime for HVAC Cooling System	Excessive Runtime for HVAC Cooling Systems	Water infiltration and flooding cause damage to interiors and services	
Damage Type	Abrupt	Gradual	Abrupt	
Damage Effect	Condition Loss	Service Life Reduction	Condition Loss	
Threshold	100	65	6	
Damage Likelihood	0.75	0.25	0.25	
Damage Extent	0.05	0.5	0.8	
Baseline	12.16	923.22	0.00	
50th Percentile				
Climate Value	17	1,020.53		
Annualized Increase		0.01		
Degradation Rate		105.27%		
Adjusted RSL		9.81		
Adjusted Alpha		1.43		
Adjusted Beta		0.85		0.83
SL Reduction	0.38	0.52		0.9
Annual Risk Premium				3,997
90th Percentile				
Climate Value	30.1	1,171.28	0.89	
Annualized Increase		0.03		
Degradation Rate		113.43%		
Adjusted RSL		9.1		
Adjusted Alpha		1.49		1.66
Adjusted Beta		0.81		0.7
SL Reduction	0.39	1.22	1.22	2.83
Annual Risk Premium				12,538



STEP 8. CALCULATE WEATHER ADJ. DEGRADATION PARAMETERS ACROSS ALL DAMAGE MODES



- Total Adjusted RSL:
 - $RSL - TotalServiceLifeReduction$
- Total Adjusted Beta:
 - If $RSL > 0$, then $\frac{Current\ Age + Total\ Adjusted\ RSL}{DesignLife}$, else beta
- Total Adjusted Alpha:
 - $Log\left(-Log\left(\frac{CurrentCI}{100}, \frac{100}{CIterminal}\right)\right), \frac{CurrentAge}{DesignLife \times TotalAdjustedBeta}$

Scenario ⓘ

IMCOM_B30_only

Only B30 for all of IMCOM

Years: 3 Hazards: 3

Filter

Systems All

Components All

Component Details

Component ⓘ : **D3030 COOLING GENERATING SYSTEMS**

Material Category ⓘ : **D303001 CHILLED WATER SYSTEMS**

Component Type: **Cooling Tower, Stainless Steel - 1000 TN**

Year Built: **2019**

Age: **3**

Design Life: **15**

Quantity: ⓘ : **1 EA**

Risk Analysis

CRV ⓘ : **\$686,880**

Risk Premium

\$3,997 | \$12,538


Service Life Reduction

0.90 yr | 2.83 yr

● 50th Percentile
● 90th Percentile

Percentile: 50% (90%) likelihood that the actual risk premium/service life reduction falls below the estimated risk premium.

Risk Rating ⓘ



Component Specific Damage

Climate Variable	Damage Mode ⓘ	Damage Type ⓘ	Damage Effect ⓘ	Threshold ⓘ	SL Reduction ⓘ
Max Temperature	Excessive Runtime for HVAC Cooling Systems	Abrupt	Condition Loss	100	0.38
Cooling Degree Days	Excessive Runtime for HVAC Cooling Systems	Gradual	Service Life Reduction	65	0.52
Rainfall (in/day)	Water infiltration and flooding cause damage to interiors and services	Abrupt	Condition Loss	6	



U.S. ARMY

STEP 9. CALCULATE ANNUAL RISK PREMIUM

33



Annual Risk Premium:

$$\frac{\textit{ComponentReplaceValue} \times \textit{TotalServiceLifeReduction}}{\textit{DesignLife} \times \textit{RemainingServiceLife}}$$



Scenario ⓘ

IMCOM_B30_only

Only B30 for all of IMCOM

Years: 3 Hazards: 3

Filter

Systems All

Components All

Component Details

Component ⓘ : **D3030 COOLING GENERATING SYSTEMS**

Material Category ⓘ : **D303001 CHILLED WATER SYSTEMS**

Component Type: **Cooling Tower, Stainless Steel - 1000 TN**

Year Built: **2019**

Age: **3**

Design Life: **15**

Quantity: ⓘ : **1 EA**

Risk Analysis

CRV ⓘ : **\$686,880**

Risk Premium

\$3,997 (50th Percentile) | \$12,538 (90th Percentile)


Service Life Reduction

0.90 yr (50th Percentile) | 2.83 yr (90th Percentile)

● 50th Percentile
● 90th Percentile


Percentile: 50% (90%) likelihood that the actual risk premium/service life reduction falls below the estimated risk premium.

Risk Rating ⓘ




Component Specific Damage


Climate Variable	Damage Mode ⓘ	Damage Type ⓘ	Damage Effect ⓘ	Threshold ⓘ	SL Reduction ⓘ
Max Temperature	Excessive Runtime for HVAC Cooling Systems	Abrupt	Condition Loss	100	0.38
Cooling Degree Days	Excessive Runtime for HVAC Cooling Systems	Gradual	Service Life Reduction	65	0.52
Rainfall (in/day)	Water infiltration and flooding cause damage to interiors and services	Abrupt	Condition Loss	6	



Incorporate impacts of climate risk on facility condition



Evaluate climate scenarios to identify potential work requirements




Prioritize facility investments that lower risk and improve resilience



U.S. ARMY

QUESTIONS?



BUILDER™



WELDER



Sustainment Management Systems (SMS) Summit 2023

NATIONAL ACADEMIES
Sciences
Engineering
Medicine